

250x150 GARBAGE EXHAUST DUCT
RISER TO ABOVE. SEAL GAP BETWEEN
DUCT AND SLAB PENETRATION WITH
MIN. 2 HRS FIRE RATED SEALANT

800x400 CARPARK EXHAUST DUCT TO
CONNECT TO MASONRY RISER ABOVE.
SEAL GAP BETWEEN DUCT AND SLAB
PENETRATION WITH MIN. 2 HRS FIRE
RATED SEALANT

450x400 PUMP ROOM INTAKE AIR
LOUVRE C/W WEATHER-PROOF
AND VERMIN MESH WIRE

SAF-01
SUPPLY AIR FAN
ON HIGH LEVEL

EF-02
EXHAUST AIR FAN
ON HIGH LEVEL

450x400 PUMP ROOM DISCHARGE
LOUVRE C/W WEATHER-PROOF
AND VERMIN MESH WIRE

450x200 WALL OPENING
C/W FIRE DAMPER AND MESH WIRE

SAF-03
250L/S WALL MOUNTED SUPPLY AIR FAN
AT H/L C/W FIRE DAMPER ON WALL
PENETRATION

6-OFF 550x250 DOUBLE
DEFLECTION C/W OBD @
350l/s EACH

200x200 TOILET EXHAUST EXTERNAL
LOUVRE C/W WEATHER-PROOF AND
VERMIN MESH WIRE

2000x1000 FREE MAKE UP AIR
INTAKE C/W WETHER-PROOF
AND VERMIN MESH WIRE


300x250 REFRIGERANT PIPEWORK
RISER TO ABOVE (TYPICAL)

2500x400 FREE MAKE UP AIR
INTAKE C/W WEATHER-PROOF
AND VERMIN MESH WIRE

12-OFF OUTDOOR CONDENSER
UNITS MOUNTED ON HIGH LEVEL

2 OFF 1500x1000 FREE MAKE UP
AIR INTAKE C/W FIRE DAMPER,
ACCESS PANEL, WEATHER-PROOF
AND VERMIN MESH WIRE

basement floor plan




No	AMENDMENT	ENG	DRAFT	DATE	No	AMENDMENT	ENG	DRAFT	DATE
B	ISSUED FOR CC	JS	SY	06-MAR-17					
A	COORDINATION ISSUE	JS	SY	20-JAN-17					
PI	PRELIMINARY ISSUE	JS	SY	08-DEC-16					

ARCHITECT
BAINI DESIGN
ABN 51 088 732 593
Office 2 / Level 4,
25-33 Old Northern Road
Baulkham Hills, NSW 2153
Phone +61 2 9639 1674
info@bainidesign.com.au
www.bainidesign.com.au
Sydney, Australia



CLIENT									



PROJECT
PROPOSED RESIDENTIAL DEVELOPMENT
1407 PACIFIC HIGHWAY,
WARRAWEE NSW 2074

SHEET SUBJECT
MECHANICAL SERVICES
BASEMENT

PROJECT 1407 PACIFIC HIGHWAY WARRAWEE NSW 2074									
DATE	DRAWN	DESIGNED	CHECKED						
AUG 2016	SY	JS	JS						
SCALE @ A1				JOB No	160721				
1:100				DWG No	M03				
AUTHORISED				REV	B				
JS									